

PUMP DATA:

MANUFACTURER, _____
 _____ MODEL NO., _____ IMP. NO., _____ MOTOR,
 _____ HP, _____ RPM, _____ VOLTS, _____ PHASE, 60 HERTZ

OPERATING CONDITIONS:

_____ GPM AT _____ TDH. _____ % EFFICIENCY

WET WELL:

SIZED FOR MINIMUM PUMP CYCLE TIME OF 10 MINUTES AND A MAXIMUM
 OF 6 PUMP STARTS PER HOUR. WORKING DEPTH _____ FT. WORKING
 VOLUME _____ GALS.

ELECTRICAL:

FEEDERS AND CONDUIT _____ MAIN SWITCH _____ POLES _____ AMPS



**ST. LUCIE COUNTY
 WATER & WASTEWATER
 CONSTRUCTION STANDARDS**

**TYPICAL LIFT
 STATION DATA**

DRAWING NUMBER: **WW-24**